



Industrie Service

Herewith it is confirmed to the company

UAB KOMFOVENT

in
LT-08200 Vilnius

based on the positive results of the completed tests at the

Calculation software „KomfoventRotor” for rotary heat exchangers for the model ranges RR-AL-... / RR-AZ-...

Stand-Alone-Version: “2.7.x.x”
DLL-Version: “2.7.x.x”

that the requirements of the certification program

RLT-RICHTLINIE Zertifizierung: 2017-11

of „Herstellerverband Raumluftechnische Geräte e. V.”
were fulfilled.

The company is allowed to use the following Certification Mark:



This certificate is valid up to and including 2025-12-31

Certificate registration number: 13/14/13 (Revision 02)



Certification Body for Products
Refrigeration and Air-Conditioning
Munich, 2019-12-03



This certificate is only valid in conjunction with the following annex (one page)



Industrie Service

Test and certification program
 „RLT-RICHTLINIE Zertifizierung“: 2017-11

Calculation software for rotary heat exchangers

Company: UAB Komfovent
 Name: KomfoventRotor
 Stand-Alone-Version: 2.7.x.x
 DLL-Version: 2.7.x.x (ARotor.dll)

The above-mentioned software can be used to calculate the following models/designs/layouts of heat exchangers.

Rotary heat exchangers:

Typ	Design	Wave height	Wheel depth	Foil thickness
RR-AL-...	Condensation	1.4 – 1.7 mm	200 mm	0.07 mm
RR-AZ-...	Enthalpy	1.4 – 1.9 mm	200 mm	0.08 mm

